

Objekt / Object: Bencinski servis KOMEL Hoče / fire station KOMEL in Hoče

REFERENCA O USPEŠNEM DELOVANJU VGRAJENEGA GASILNEGA SISTEMA
NA BENCINSKEM SERVISU KOMEL HOČE

REFERENCE ABOUT SUCCESSFUL FIRE EXTINGUISHING ACTIVATION AT
PETROL STATION KOMEL HOČE

Opis dogodka: februarja 2010 je na BS Komel prišlo do požara na tovornjaku za mešanje betona
The event: February 2010 at BS Komel occurred a fire on a truck for mixing concrete

OPIS DELOVANJA:

Na tovornjaku za mešanje betona je prišlo do vžiga reduktorja za mešanje betona. Vozilo je bilo ustavljen pod nadstrešnico BS. Sistem detekcije je aktiviral gasilni sistem, ki je uspešno pogasil požar na reduktorju vozila.
Aktivacija sistema ni povzročila nobene dodatne škode, zato so bile posledice aktiviranja zelo hitro sanirane. Po pogasitvi je bil BS očiščen z vodo in je takoj lahko nadaljeval z delom, ker oprema na BS ni bila poškodovana.

DESCRIPTION OF THE OPERATION:

On a truck for mixing concrete came to an ignition of reducer for mixing concrete. Vehicle was parked under fire station. System of detection activated extinguishing system that successfully extinguished fire on a vehicle reducer.
System activation alone caused no additional damage, therefore consequence of activation were quickly reorganized. After system activation fire station was cleaned with water and could promptly continue working cause no equipment was damaged.

Priloga/Enclosed:
• fotografija / photo

Referenco potrjuje / Confirmed by:

g. Slavko KOMEL
direktor podjetja

Hoče, 30.08.2010

